

POLLUTION MONITORING DATA

Jerilderie Sewerage Treatment Works



Environment Protection Licence No. 1692

Link to full licence on EPA website: [Jerilderie Licence 1692](#)

Licensee: Murrumbidgee Council

Licensee's Address: PO Box 96, Jerilderie NSW 2716

Facility Address: Wilson Road, Jerilderie NSW 2716

Monitoring Point 4

Date Sample: 5 September 2017

Date Obtained: 19 September 2017

Date Published: 3 October 2017

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	7	20
Conductivity	Microsiemens per centimetre	Quarterly	1050	
Nitrogen (total)	Milligrams per litre	Quarterly	31	
Oil and Grease	Milligrams per litre	Quarterly	<1	10
pH	Milligrams per litre	Quarterly	7.7	
Phosphorus (total)	Milligrams per litre	Quarterly	9.18	
Total Suspended Solids	Milligrams per litre	Quarterly	13	30